



3320 Nazareth Road, Easton, PA 18045

Phn: 800-949-3445

Fax: 610-438-4472

E-mail: info@electrocellsystems.com

February 2023

ELECTROCELL PERFORMANCE REPORT MAJOR AUTOMOTIVE MANUFACTURING FACILITY

Please review the results of our recently installed system at one of our many large automobile manufacturing applications.

This system was installed in June 2022 on a 6000-ton loop comprised of three 2000-ton chillers. This is just one of five 6000-ton loops. The customer was able to supply us with information to calculate kW per ton. ElectroCell initially estimated a minimum of 10% kw/ton reduction. Sample trending logged all points in one-hour increments (24 per day) throughout each month. We will continue with these calculations throughout the year.

ElectroCell additionally conducted a 3rd party lab test for both before and after particle analysis (see attached).

Any questions on the attached do not hesitate to contact me.

Paul Q. McLaine, President


ElectroCell Systems

Ofc: 800-949-3445

Cell: 484-894-1608



**Major Alabama Automotive Manufacturer
6,000-Ton multi-chiller open loop application (one of five loops)
kW per ton comparison**



**EC-6000 System "Before and After" kW/ton results
ElectroCell System Installed June 2022**

MAJOR AUTOMOTIVE MANUFACTURER ALABAMA MONTHLY COMPARISON

| JUL 2021 | Average Entering Chilled Water Temp (deg F) | Average Leaving Chilled Water Temp (deg F) | Average Chiller Evaporator Flow (gpm) | Average Chiller Input Power (kW) | Average Cooling Load (tons) | Average Kw/Ton |
|---------------------|---|--|---|-------------------------------------|--------------------------------|--------------------|
| Chiller 3 | 56.80 | 45.08 | 2686.98 | 1026.69 | 1311.76 | 0.782680060 |
| Chiller 4 | 59.00 | 46.29 | 2363.92 | 980.82 | 1252.25 | 0.783247305 |
| Chiller 5 | 57.94 | 45.78 | 1673.87 | 824.55 | 848.03 | 0.972312814 |
| AVG | 57.91 | 45.72 | 2241.59 | 944.02 | 1137.35 | 0.846080059 |

| JUL 2022 | Average Entering Chilled Water Temp (deg F) | Average Leaving Chilled Water Temp (deg F) | Average Chiller Evaporator Flow (gpm) | Average Chiller Input Power (kW) | Average Cooling Load (tons) | Average Kw/Ton |
|---------------------|---|--|---|-------------------------------------|--------------------------------|-------------------|
| Chiller 3 | 58.48 | 43.26 | 1717.14 | 595.66 | 1088.88 | 0.547038334 |
| Chiller 4 | 60.19 | 46.32 | 2645.48 | 1162.42 | 1529.05 | 0.760223071 |
| Chiller 5 | 57.25 | 45.03 | 2398.26 | 1081.26 | 1221.11 | 0.885469334 |

| | | | | | | |
|----------------|--------------|--------------|----------------|---------------|----------------|--------------------|
| AVERAGE | 58.64 | 44.87 | 2253.63 | 946.45 | 1279.68 | 0.730910246 |
|----------------|--------------|--------------|----------------|---------------|----------------|--------------------|

| | |
|--------------------------------------|---------------|
| JULY 2022 kW Reduction %: | 13.61% |
|--------------------------------------|---------------|

MAJOR AUTOMOTIVE MANUFACTURER ALABAMA MONTHLY COMPARISON

| AUG 2021 | Average Entering Chilled Water Temp (deg F) | Average Leaving Chilled Water Temp (deg F) | Average Chiller Evaporator Flow (gpm) | Average Chiller Input Power (kW) | Average Cooling Load (tons) | Average Kw/Ton |
|--------------------------------|---|--|---|-------------------------------------|--------------------------------|-------------------|
| Chiller 3 | 56.71 | 44.85 | 2862.21 | 1019.01 | 1414.78 | 0.720259192 |
| Chiller 4 | 58.25 | 45.23 | 2837.91 | 1103.24 | 1539.63 | 0.716562511 |
| Chiller 5 | 56.30 | 44.72 | 2494.21 | 1081.76 | 1203.82 | 0.898605281 |
| AVERAGE | 57.09 | 44.93 | 2731.45 | 1068.00 | 1386.08 | 0.778475661 |
| AUG 2022 | Average Entering Chilled Water Temp (deg F) | Average Leaving Chilled Water Temp (deg F) | Average Chiller Evaporator Flow (gpm) | Average Chiller Input Power (kW) | Average Cooling Load (tons) | Average Kw/Ton |
| Chiller 3 | 60.71 | 44.97 | 1365.39 | 554.98 | 895.93 | 0.619450226 |
| Chiller 4 | 67.35 | 49.80 | 1808.94 | 783.72 | 1322.57 | 0.592571816 |
| Chiller 5 | 60.43 | 45.66 | 2144.47 | 951.35 | 1319.53 | 0.720973529 |
| AVERAGE | 62.83 | 46.81 | 1772.93 | 763.35 | 1179.34 | 0.644331857 |
| AUGUST 2022 kW Reduction %: | | | | | | 17.23% |

MAJOR AUTOMOTIVE MANUFACTURER ALABAMA MONTHLY COMPARISON

| SEP 2021 | Average Entering Chilled Water Temp (deg F) | Average Leaving Chilled Water Temp (deg F) | Average Chiller Evaporator Flow (gpm) | Average Chiller Input Power (kW) | Average Cooling Load (tons) | Average Kw/Ton |
|---------------------|---|--|---|-------------------------------------|--------------------------------|--------------------|
| Chiller 3 | 54.69 | 44.58 | 2805.86 | 841.91 | 1181.92 | 0.712319578 |
| Chiller 4 | 56.84 | 46.02 | 2479.07 | 846.65 | 1117.29 | 0.757769537 |
| Chiller 5 | 60.36 | 46.64 | 625.21 | 320.77 | 357.46 | 0.897356614 |
| AVERAGE | 57.30 | 45.75 | 1970.05 | 669.77 | 885.56 | 0.789148577 |

| SEP 2022 | Average Entering Chilled Water Temp (deg F) | Average Leaving Chilled Water Temp (deg F) | Average Chiller Evaporator Flow (gpm) | Average Chiller Input Power (kW) | Average Cooling Load (tons) | Average Kw/Ton |
|---------------------|---|--|---|-------------------------------------|--------------------------------|-------------------|
| Chiller 3 | 59.33 | 45.20 | 2223.76 | 727.41 | 1308.90 | 0.555743857 |
| Chiller 4 | 72.38 | 52.48 | 948.52 | 491.16 | 786.61 | 0.624399192 |
| Chiller 5 | 55.66 | 44.69 | 2693.60 | 1036.65 | 1231.40 | 0.841847648 |

| | | | | | | |
|----------------|--------------|--------------|----------------|---------------|----------------|--------------------|
| AVERAGE | 62.46 | 47.46 | 1955.29 | 751.74 | 1108.97 | 0.673996899 |
|----------------|--------------|--------------|----------------|---------------|----------------|--------------------|

| | |
|---|---------------|
| SEPTEMBER 2022 kW Reduction %: | 14.59% |
|---|---------------|



PARTICLE ANALYSIS

**MAJOR AUTOMOTIVE MANUFACTURING FACILITY
Lincoln, AL**

Source: Central Plant Chiller Open Loop

Electro Cell System: XCell-6000 Particle Precipitator



**99.5%
Particle
Reduction
after
32 Days**

TEST METHOD: All tests completed by independent third-party laboratory. Samples analyzed by electro-optical particle analyzer employing the light scattering principle of operation with filtered water and particle data corrected. Stirring was continuous.

BASELINE SAMPLE - 07-Jun-2022
Prior to **ElectroCell** Start-up

POST INSTALL SAMPLE - 09-Jul-2022
with **ElectroCell** System

**PARTICLE COUNTS PER 100mL
TEST PORTION**

**PARTICLE COUNTS PER 100mL
TEST PORTION**

| | |
|-----------------------|------------------|
| 1 - 3 micron: | 5,765,160 |
| 3 - 5 micron: | 1,085,480 |
| 5 - 10 micron: | 855,080 |
| 10 - 15 micron: | 152,720 |
| 15 - 25 micron: | 116,440 |
| Over 25 micron: | <u>168,800</u> |
| TOTAL / 100mL: | 8,143,680 |

| | |
|-----------------------|---------------|
| 1 - 3 micron: | 12,771 |
| 3 - 5 micron: | 4,843 |
| 5 - 10 micron: | 3,812 |
| 10 - 15 micron: | 874 |
| 15 - 25 micron: | 1,153 |
| Over 25 micron: | <u>849</u> |
| TOTAL / 100mL: | 24,302 |

**SOLIDS PER 100 LITERS
OF SYSTEM VOLUME (mm³)**

**SOLIDS PER 100 LITERS
OF SYSTEM VOLUME (mm³)**

| | |
|----------------------------|-------------------|
| 1 - 5 micron: | 115.59 |
| 5 - 10 micron: | 360.84 |
| Over 10 micron: | <u>114,044.18</u> |
| TOTAL / 100 Liters: | 114,520.61 |

1145 ppm

| | |
|----------------------------|---------------|
| 1 - 5 micron: | 0.41 |
| 5 - 10 micron: | 1.61 |
| Over 10 micron: | <u>578.16</u> |
| TOTAL / 100 Liters: | 580.18 |

6 ppm

Electro Cell Systems

3320 Nazareth Road, Easton, PA 18045

Phn: (800) 949-3445 Fax: (610) 438-4472 email: info@electrocellsystems.com